

**From:** Jeff Joyner  
**Cc:** "[tamf@aol.com](mailto:tamf@aol.com)"; [joesmcp@aol.com](mailto:joesmcp@aol.com); Art Lawrence ([art@lawrencebackhoe.com](mailto:art@lawrencebackhoe.com)); [janine@lawrencebackhoe.com](mailto:janine@lawrencebackhoe.com); [andy@taylorbackhoe.com](mailto:andy@taylorbackhoe.com); [janet@taylorbackhoe.com](mailto:janet@taylorbackhoe.com); "[mike@taylorbackhoe.com](mailto:mike@taylorbackhoe.com)"; "[soconnell@sfe-inc.com](mailto:soconnell@sfe-inc.com)"; "[rdunham@sfe-inc.com](mailto:rdunham@sfe-inc.com)"  
**Subject:** RE: Campus Parkway Addenda  
**Date:** Tuesday, December 04, 2018 7:15:00 AM

---

Hi All!

The Q&A period for the Campus Parkway project has closed. I have posted the revised bid docs dated 12/3/18 on the web along with this Addenda email string. Please have your bids to the MID Receptionist before 2pm Local Time on Tuesday, December 11, 2018.

Thanks for Your participation and Good Luck on Your bids!

-jeff

---

**From:** Jeff Joyner  
**Sent:** Monday, December 03, 2018 11:41 AM  
**Cc:** 'tamf@aol.com' <[tamf@aol.com](mailto:tamf@aol.com)>; [joesmcp@aol.com](mailto:joesmcp@aol.com); Art Lawrence ([art@lawrencebackhoe.com](mailto:art@lawrencebackhoe.com)) <[art@lawrencebackhoe.com](mailto:art@lawrencebackhoe.com)>; [janine@lawrencebackhoe.com](mailto:janine@lawrencebackhoe.com); [andy@taylorbackhoe.com](mailto:andy@taylorbackhoe.com); [janet@taylorbackhoe.com](mailto:janet@taylorbackhoe.com); 'mike@taylorbackhoe.com' <[mike@taylorbackhoe.com](mailto:mike@taylorbackhoe.com)>; 'soconnell@sfe-inc.com' <[soconnell@sfe-inc.com](mailto:soconnell@sfe-inc.com)>; 'rdunham@sfe-inc.com' <[rdunham@sfe-inc.com](mailto:rdunham@sfe-inc.com)>  
**Subject:** RE: Campus Parkway Addenda

Hi All!

Engineer's estimate for total project cost is **\$2,219,213**.

Also, attached is the revised bid docs with modified proposal section with space for Change Order Markup %. Below is a snip of the revised portion. Please make sure that your bid docs are dated 12/3/18. I will also place the modified bid docs(dated 12/3/18) on the web later today.

Thanks!

-jeff

**BID PROPOSAL  
FOR  
CAMPUS PARKWAY EXTENSION  
MID IFB 2018-13**

**BID PRICE** \$ \_\_\_\_\_  
(Bid price shall be in accordance with attached MID Specifications and Drawings)

\$ \_\_\_\_\_  
Written Bid Price

**CHANGE ORDER MARKUP %** \_\_\_\_\_  
(Change Orders to be Time & Material based with Markup)

In accordance with the "Invitation to Bidders", the undersigned, as bidder, declares that he has carefully examined the location of the proposed work, the plans and specifications, read the accompanying instructions to bidders, the contract forms, the bond forms, and agrees that if his proposal is accepted he will contract, on the required form, with the District to, at his own cost, do all of the work and furnish all of the equipment, materials and labor necessary to complete the work in the manner and in the time described in the plans and

---

**From:** Jeff Joyner  
**Sent:** Wednesday, November 28, 2018 12:04 PM  
**Cc:** 'tamf@aol.com' <[tamf@aol.com](mailto:tamf@aol.com)>; [joesmcp@aol.com](mailto:joesmcp@aol.com); Art Lawrence ([art@lawrencebackhoe.com](mailto:art@lawrencebackhoe.com)) <[art@lawrencebackhoe.com](mailto:art@lawrencebackhoe.com)>; [janine@lawrencebackhoe.com](mailto:janine@lawrencebackhoe.com); [andy@taylorbackhoe.com](mailto:andy@taylorbackhoe.com); [janet@taylorbackhoe.com](mailto:janet@taylorbackhoe.com); 'mike@taylorbackhoe.com' <[mike@taylorbackhoe.com](mailto:mike@taylorbackhoe.com)>; 'soconnell@sfe-inc.com' <[soconnell@sfe-inc.com](mailto:soconnell@sfe-inc.com)>  
**Subject:** Campus Parkway Addenda

Hi All!

This will be the official email string for addenda on the Campus Parkway Extension Project!  
To recap our Pre-Bid Meeting:

**\*All crossings of existing irrigation lines, gas lines, electric lines, fuel lines, communication lines, sewer lines, water lines, storm drain lines, traffic loops, etc. (known or unknown) are to be included in your bids! There will be no change orders issued for crossing over or under any existing facilities! Relocation/modification of the existing landscape irrigation system along Campus Parkway to be included in your bids!**

**\*Caltrans specific traffic control/signage/flagging/barricades may be required along HWY 140 and will be evaluated on a "cost-plus" basis. Please provide a mark-up percentage for HWY 140 traffic control with your bids, I will modify the bid forms to include a space for your proposed mark-up percentage. All traffic control/signage/labor other than HWY 140 to be included in your bids.**

**\*MID will provide traffic control engineering drawings.**

**\*MID to provide trench, vault and ROW staking.**

**\*Vault spacing may be slightly adjusted to provide adequate clearance for the 22-degree bends to transition from the vaults into the main trench.**

**\*All work within the County's Campus Parkway project will need to be coordinated with the County's project management team (NV5). Some work locations/schedule adjustments may be required and shall be included in your bids.**

**\*It is expected that City, County and Caltrans encroachment permits should be approved by mid-January(maybe sooner) and the BNSF Railroad permit approved by end of January.**

Please email any further questions directly to me.

Thanks!

-jeff

**JEFF JOYNER**

**MERCED IRRIGATION DISTRICT**

744 W. 20<sup>TH</sup> STREET

MERCED, CA 95340

(209)722-5761